


VAMC Chillicothee Rehab B18 Machine Room

Department of Veterans Affairs Medical Center
17273 State Route 104
Chillicothee, Ohio 45601

JOHN POE ARCHITECTS
ARCHITECTURE PLANNING INTERIOR DESIGN
116 EAST THIRD STREET
DAYTON, OHIO 45402
937.461.3290 P
937.461.0260 F

HEAPY ENGINEERING
MECHANICAL ELECTRICAL COMMISSIONING TECHNOLOGY
1400 WEST DOROTHY LANE
DAYTON, OH 45409
937.224.0861 P
937.224.5777 F

VICINITY MAP



DRAWING INDEX

A101	Cover Sheet
A301	Floor Plans
18M001	Legend, Index and Schedules
18M101	Floor Plans Plumbing and HVAC
18E001	Symbols
18E501	Details
18E601	Partial Primary Electric Single Line
18E602	Partial Building Secondary Electric Single Line
18ES101	Electrical Site Plan - Removals & New Work
18ED101	Basement Floor Plans - Removals
18EP101	Basement Floor Plans - New Work
18EL101	First and Second Floor Plan - Lighting & Power

VAMC Chillicothee Rehab B18 Machine Room


FOR:
Department of Veterans Affairs Medical Center
17273 State Route 104
Chillicothee, Ohio 45601

GENERAL CONSTRUCTION NOTES

- * PLEASE NOTE THAT THE TERM PROJECT ENGINEER REFERS TO THE CONTRACTING OFFICER'S TECHNICAL REPRESENTATIVE.
- SPRINKLER DESIGN BASED ON FIRE PROTECTION DRAWINGS AND SPECIFICATIONS AS SUBMITTED BY THE M.E.P. ENGINEERS WILL BE SUBJECT TO AN INDEPENDENT REVIEW BY A CERTIFIED REVIEWER. THE FIRE PROTECTION CONTRACTOR IS RESPONSIBLE FOR MAKING ALL ARRANGEMENTS FOR THIS INDEPENDENT REVIEW.
 - ALL WORK SHALL COMPLY WITH ALL APPLICABLE LOCAL, STATE OR, NATIONAL CODES, RULES, ORDINANCES AND REGULATIONS INCLUDING THE AMERICAN DISABILITIES ACT (ADA) AND THE AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI) GUIDELINES.
 - IT IS INTENDED THAT THE DOCUMENTS INDICATE A NEW FINISH (I.E. PAINT, ACOUSTIC CEILING, FLOOR TILE, ETC.) ON ALL EXPOSED SURFACES OF THE BUILDING. WHERE A SPECIFIC FINISH IS NOT INDICATED AT ANY GIVEN LOCATION THE CONTRACTOR SHALL PROVIDE THE FINISH INDICATED FOR OTHER SIMILAR SURFACES.
 - THE PROJECT ENGINEER SHALL PROVIDE TEMPORARY ACCESS TO SERVICES REQUIRED TO FACILITATE THE WORK INDICATED, INCLUDING BUT NOT LIMITED TO THE FOLLOWING: POWER, LIGHTING, HEAT, AND WATER.
 - IT IS THE RESPONSIBILITY OF THE GENERAL CONTRACTOR TO NOTIFY THE PROJECT ENGINEER OF ANY WORK WHICH MIGHT REQUIRE INTERRUPTION OF UTILITY SERVICES, CAUSE NOISE, OR CREATE VIBRATION PRIOR TO THE COMMENCEMENT OF THIS WORK. THE CONTRACTOR'S WORK AND SCHEDULE SHALL BE APPROVED AND COORDINATED BEFORE HAND WITH THE PROJECT ENGINEER AND/OR ARCHITECT. SEE GENERAL CONDITIONS FOR FURTHER DETAIL.
 - THE GENERAL CONTRACTOR SHALL COMPLY WITH ALL APPLICABLE PROVISIONS OF THE SPECIFICATIONS, INCLUDING ALL GENERAL CONDITIONS, SUPPLEMENTARY GENERAL CONDITIONS, AND MATERIAL AND CONSTRUCTION PROVISIONS, WHICH APPLY TO MATERIALS OR CONSTRUCTION METHODS REQUIRED BY THIS PROJECT.
 - PRIOR TO BIDDING, THE GENERAL CONTRACTOR SHALL VISIT SITE, EXAMINE, AND ACCEPT ALL EXISTING CONDITIONS. DATES FOR SITE VISITS WILL BE POSTED IN THE SPECIFICATIONS. UNSCHEDULED VISITS WILL NOT BE ALLOWED.
 - DO NOT PAINT ANY CAULKING OR SEALANTS WHICH ARE SUBJECT TO MOVEMENT - CONTROL JOINTS SHALL BE CAULKED AFTER PAINT AND SPECIAL COATING APPLICATIONS. PROVIDE CAULKING OR SEALANTS IN COLORS WHICH MATCH ADJACENT FINISHED SURFACE COLORS.
 - VERIFY ALL CONDITIONS AND DIMENSIONS IN THE FIELD BEFORE FABRICATING ANY MATERIALS.
 - ALL EXISTING CONSTRUCTION TO REMAIN THAT ARE DAMAGED OR DISTURBED DURING CONSTRUCTION SHALL BE PATCHED OR RESTORED AS REQUIRED TO MATCH EXISTING ADJACENT CONSTRUCTION UNLESS OTHERWISE INDICATED. CONTRACTOR TO PATCH AND REPAIR EXISTING CONSTRUCTION REMOVED OR DISTURBED BY WORK UNDER THEIR CONTRACT TO MATCH EXISTING ADJACENT UNLESS OTHERWISE NOTED.
 - IT IS THE INTENT OF THE DOCUMENTS TO INDICATE COMPLETE AND OPERATIONAL SYSTEMS (I.E. STRUCTURAL, HVAC, PLUMBING, ELECTRICAL AND ETC.). THE CONTRACTOR SHALL PROVIDE THE SYSTEMS AS OPERATIONAL SYSTEMS WHICH COMPLY WITH APPLICABLE CODES AND REGULATIONS. THIS NOTE SHALL BE LIMITED TO THE SYSTEMS AS INDICATED BY THE DOCUMENTS AND SHALL NOT INCLUDE CHANGES TO THE SYSTEMS WHICH ALTER INDICATED CAPACITIES, OPERATIONAL CHARACTERISTICS, ETC.
 - THE GENERAL CONTRACTOR SHALL PROVIDE FIRE-RETARDANT TREATED 2X BLOCKING IN THE STUD CAVITY AT ALL LOCATIONS REQUIRED TO PROVIDE SOLID ANCHORAGE OF WALL SUPPORTED ITEMS INDICATED BY THE DRAWINGS, INCLUDING BUT NOT LIMITED TO: GRAB BARS, SHELVING, CABINETS, AND KITCHEN EQUIPMENT. CONTRACTORS OPTION TO PROVIDE GALV. 16 GA BY THE DEPTH OF THE WALL METAL STUDS AS BLOCKING UNLESS WOOD BLOCKING IS SPECIFICALLY CALLED FOR BY THE MANUFACTURER.
 - ALL WOOD BLOCKING, MISC. FRAMING, PANELS, ETC THAT ARE TO BE USED SHALL BE FIRE-RETARDANT TREATED.
 - THE GENERAL CONTRACTOR SHALL CONTACT THE PROJECT ENGINEER FOR INFORMATION CONCERNING ALL SIGNAGE WHICH SHALL BE PROVIDED BY THE OWNER, AND SHALL MAKE PROVISIONS FOR INSTALLATION OF SUCH SIGNAGE, INCLUDING VERIFICATION OF DIMENSIONS (ADEQUATE SPACE AT THE DESIRED INSTALLATION LOCATION), AND SHALL BRING ANY CONFLICTS TO THE ATTENTION OF THE PROJECT ENGINEER AND THE ARCHITECT.
 - THE GENERAL CONTRACTOR SHALL CONTACT THE PROJECT ENGINEER TO VERIFY THE SIZES OF ALL EQUIPMENT OR FIXTURES TO BE INSTALLED IN THE BUILDING, AND SHALL MAKE SPECIAL PROVISIONS FOR INSTALLATION OF ANY EQUIPMENT WHICH IS TOO LARGE TO FIT THROUGH A FINISHED OPENING.
 - ALL CONTRACTORS SHALL BE RESPONSIBLE TO PATCH AND REPAIR ALL SURFACES WHERE EXISTING CONSTRUCTION IS REMOVED OR DISTURBED BY WORK UNDER THEIR CONTRACT.
 - THE CONTRACTOR IN CONJUNCTION WITH HIS WORK SHALL BE RESPONSIBLE TO PATCH AND REPAIR ALL EXISTING SUBSTRATES AND FINISHES INCLUDING BUT NOT LIMITED TO EXISTING WALLS, FLOORS, BASES, WAINSCOTS, CEILINGS, WINDOWS, WINDOW TRIM, WOOD WORK, DOORS, FRAMES, ETC. (UNLESS INDICATED OTHERWISE) AND PREPARE AREAS AS REQUIRED FOR NEW CONSTRUCTION FINISHES. WHERE WORK IS PERFORMED AND NO FINISH IS SPECIFICALLY INDICATED THE CONTRACTOR IS RESPONSIBLE TO PATCH, REPAIR AND PAINT TO MATCH ALL EXISTING ADJACENT MATERIALS, FINISH AND PAINT ALL WORK TO PROVIDE A COMPLETE, FINISHED, WORKMANLIKE JOB, ALL SUBJECT TO THE APPROVAL OF THE ARCHITECT.
 - PATCH ALL EXISTING WALLS AND CEILINGS THAT ARE TO REMAIN (EXCEPT WHERE NOTED) AS REQUIRED TO PROVIDE A SOUND BASE FOR NEW FINISHES SUCH AS PAINT, ETC. ALL PATCHING TO MATCH EXISTING ADJACENT SURROUNDING AREAS AND SURFACES.
 - IN ADDITION TO SPECIFIC REQUIREMENTS, THE GENERAL INTENT OF PAINTING AND TRANSPARENT FINISHES IS AS FOLLOWS: WHERE SURFACES ARE INDICATED TO BE PAINTED OR TRANSPARENT FINISH APPLIED, ALL OPENINGS, NEW AND EXISTING, INCLUDING WINDOWS, DOORS, FRAMES, TRIM, BASE, ETC. SHALL BE FINISHED OR REFINISHED IN CONJUNCTION WITH SURROUNDING WORK. WHERE SURFACES ARE NOT INDICATED TO BE PAINTED OR TRANSPARENT FINISH APPLIED IN THIS CONTRACT, ITEMS OF NEW WORK OR REPAIR WORK ONLY SUCH AS WALLS, CEILING, DOORS, FLOORS, WINDOWS, ETC. SHALL BE FINISHED TO MATCH EXISTING ADJACENT FINISHES. EXISTING ADJACENT FINISH SHALL REMAIN. SEE ROOM FINISH SCHEDULE AND DOOR SCHEDULE FOR FINISHES. THE CONTRACTOR SHALL VERIFY IN THE FIELD ALL FINISHES WITH THE ARCHITECT PRIOR TO EXECUTION OF THE WORK.
 - ALL SUSPENDED ITEMS SUCH AS CEILINGS, DUCTS, PIPES, CONDUITS, ETC., SHALL BE SUSPENDED (ATTACHED) DIRECTLY TO STRUCTURE AND SHALL NOT BE ATTACHED OR ANCHORED TO EXISTING PLASTER, ACOUSTIC TILE, ETC.
 - ALL PENETRATIONS SUCH AS NEW OR EXISTING DUCTS, CONDUITS, PIPING, ELECTRICAL OUTLETS, LIGHT SWITCHES, RECESSED DEVICES OR ITEMS, HOLES, VOIDS, CRACKS, ETC. IN ALL EXISTING, MODIFIED AND NEW CORRIDOR WALLS, SMOKE PARTITIONS, AND FLOOR SLABS SHALL BE SEALED TO PREVENT PASSAGE OF ANY SMOKE, FLAME, GASES, ETC. SEE PLUMBING HVAC, FIRE PROTECTION, ELECTRICAL, ETC. DRAWINGS AND SPECIFICATIONS.
 - WHERE NEW CONSTRUCTION (I.E. DOORS, FRAMES, CASEWORK, EQUIPMENT, ETC.) IS INDICATED TO BE INSTALLED IN EXISTING CONSTRUCTION, THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS FOR PROPER FIT AND FOR ACCESS INTO THE BUILDING PRIOR TO SHOP DRAWING SUBMITTAL, ORDERING AND DELIVERING TO THE SITE.

GRAPHIC SYMBOLS

	ELEVATION		CEILING HEIGHT/ FINISH DESIGNATION
	SECTION/DETAIL NUMBER		COLUMN GRID
	DRAWING NUMBER		ROOM NUMBER
	NOTE		WINDOW OPENING
	BEARING		DOOR OPENING
	REVISION		



This drawing and all original design work contained herein represents the unpublished work of John Poe Architects, Inc. intended solely for use related to the project listed herein and shall not be reproduced in any fashion without the expressed written consent of John Poe Architects, Inc.

COPYRIGHT 2013


VA PROJECT NO. 538-12-119
JPA PROJECT NO. 12022.00

SET NO.


DATE 12/27/2012

A101


three inches = one foot
one and one-half inches = one foot
one inch = one foot
three-quarters inch = one foot
one-half inch = one foot
one-third inch = one foot
three-eighths inch = one foot
one-quarter inch = one foot
one-eighth inch = one foot




1
Frame Types
Scale: 1/4" = 1'-0"




F
DOOR TYPES
Scale: 1/4" = 1'-0"




2
Generator Slab and Transformer Slab Detail
Scale: 1 1/2" = 1'-0"



H1




J1




S1


DOOR DETAILS
Scale: 1 1/2" = 1'-0"




N
New Work Plan - Basement
Scale: 1/4" = 1'-0"




N
Demolition Plan - Basement
Scale: 1/4" = 1'-0"




N
Site Plan
Scale: 1" = 20'-0"



1
Bollard Detail
Scale: 3/4" = 1'-0"



3
Enlarged Site Plan
Scale: 1/4" = 1'-0"



N
Key Plan
Scale: 1" = 30'-0"

GENERAL NOTES

- All dimensions are taken to face of gypsum wallboard or unit masonry.
- Edge of all door jambs at hinge side not otherwise indicated are to be 6" from the face of intersecting walls. Edge of all door jambs at strike side not otherwise located are to be 18" minimum from the face of intersecting walls.
- All wood blocking to be fire retardant treated.

DRAWING NOTES

- Remove existing door and frame.
- New custom Hollow Metal Door and Frame to match existing opening size. See details this sheet. Frame type 1, door type F, head detail H1, jamb detail J1, and sill detail S1. Hardware set 01.
- Concrete filled steel bollard.
- 6" o.d. steel bollard.
- New concrete footing.
- Existing concrete wall to remain.
- Sealant both sides of frame. Provide backer rod at all exterior locations.
- Grout frames full.
- Hollow metal frame.
- New door sill.
- Existing concrete slab to remain.
- New domed drain cover.
- Slope to drain at a max slope of 25%.
- Clean compacted gravel subgrade.
- Compacted subgrade.
- #4 rebar @ 12" O.C. horizontally & vertically.
- Chamfer corner @ all edges.
- Field verify & locate new generator & transformer as close to existing as possible while maintaining existing until construction is complete.
- Re-grade sloping away from concrete pad to drain at Max. slope of 25%.
- Techy Mission Arborvitae, spaced 4' O.C. min. Provide plantings with 16" to 18" root balls in diameter.
- This edge shall be at current grade.
- Concrete filled steel bollard. See Detail 1/A301. See Electrical Drawings.
- 4" thick concrete slab over clean compacted gravel sub-grade.
- Existing sidewalk to remain.

JOHN POE ARCHITECTS

116 EAST THIRD STREET
DAYTON, OHIO
45402-2130
937-461-3280 PHONE
937-461-0260 FAX
jpa@johnpoe.com



Floor Plans

Project Title
VAMC Chillicothe Rehab B18
Machine Room

Building
Number

18

Checked

JR

Drawn

MA


Location
Chillicothe, Ohio

Date
12/27/2012

Project No.
VA Project No. 538-12-119
JPA Project No. 12022.00

Drawing Number
A301

Dwg. of



A. CONTRACTOR SHALL NOT DISRUPT ANY EQUIPMENT OF THE ADVANCED METERING SYSTEM WITHOUT PROVIDING AN ACTION PLAN TO RESTORE ALL EQUIPMENT WITHIN TEN (10) CALENDAR DAYS.

B. ALL ELECTRICAL SPACES FOR WIRE SIZES 6 AWG AND LARGER SHALL BE HYDRAULIC CRIMP TYPE.

C. THESE NOTES APPLY EQUALLY TO THE FULL SET OF DOCUMENTS.

D. SITE VISIT(S) SHALL BE AS OUTLINED IN PROJECT SPECIFICATIONS.

E. ANY ASBESTOS WORK PERFORMED AS PART OF THIS PROJECT SHALL BE COMPLETED PRIOR TO STARTING ANY OTHER PROJECT SITE WORK.

F. THE NOTES AND SYMBOLS SET DOWN ON THESE DRAWINGS ARE FOR THE GUIDANCE OF THE CONTRACTOR INVOLVED IN THE PROJECT AND MUST BE FOLLOWED TO EXECUTE THE WORK AS INTENDED.

G. THE CONTRACTORS SHALL REFER TO ALL SPECIFICATION SECTIONS, AND ELECTRICAL DRAWINGS FOR DETAILS OF BUILDING CONSTRUCTION TO ENSURE SPACE AND SATISFACTORY ARRANGEMENT FOR THEIR WORK. THE VARIOUS DRAWINGS COMPRISING THE SET ARE INTERDEPENDENT AND MUST BE USED JOINTLY AT ALL TIMES. EACH CONTRACTOR SHOULD REFER TO THE GENERAL REQUIREMENTS OF THE CONTRACT. THESE NOTES AND SYMBOLS SET DOWN ON THE DRAWINGS ARE FOR THE GUIDANCE OF ALL TRADES INVOLVED IN THE PROJECT AND MUST BE FOLLOWED TO EXECUTE THE WORK AS INTENDED. IF DISCREPANCIES OCCUR, CONTACT THE COTR THRU THE CONTRACTING OFFICER FOR CLARIFICATION BEFORE PROCEEDING.

H. IN ACCORDANCE WITH GENERALLY ACCEPTED CONSTRUCTION PRACTICES, THE CONTRACTOR WILL BE SOLELY AND COMPLETELY RESPONSIBLE FOR THE CONDITIONS ON THE JOB SITE, INCLUDING SAFETY OF ALL PERSONS AND PROPERTY DURING PERFORMANCE OF THE WORK. THIS WILL APPLY CONTINUOUSLY AND NOT BE LIMITED TO NON-WORKING HOURS. SEE SPECIFICATIONS FOR MORE SPECIFIC DETAILS ON RESPONSIBILITIES.

	DELTA CONNECTION
	MOTOR, SINGLE-PHASE
	MOTOR, THREE-PHASE
	TRANSFORMER
	WYE CONNECTION
	EARTH GROUND
	JUNCTION BOX
	PULL BOX
	NORMALLY CLOSED RELAY CONTACT
	NORMALLY OPEN RELAY CONTACT
	FUSE WITH RATING
	MOLDED CASE CIRCUIT BREAKER
	LOW-VOLTAGE DRAWOUT AIR CIRCUIT BREAKER
	HIGH-VOLTAGE OIL CIRCUIT BREAKER
	HIGH-VOLTAGE DRAWOUT AIR CIRCUIT BREAKER
	SWITCH AND FUSE UNIT
	GENERATOR, POWER
	POTHEAD
	STRESS CONE
	LIGHTNING ARRESTER
	METER
	AMMETER
	VOLTMETER
	WATTMETER
	WATT-HOUR METER

	DISCONNECT SWITCH, FUSED
	DISCONNECT SWITCH, UNFUSED
	STARTER, COMBINATION WITH DISCONNECT SWITCH
	STARTER OR MOTOR CONTROLLER
	VARIABLE FREQUENCY DRIVE
	MOTOR
	TRANSFORMER, PLAN
	WYE CONNECTION
	EARTH GROUND
	JUNCTION BOX
	DISTRIBUTION PANEL
	PANELBOARD CABINET, FLUSH MOUNTED
	PANELBOARD CABINET, SURFACE MOUNTED

	3	DASH SYMBOL INDICATES PARTICULAR OUTLET OR DEVICE TO BE REMOVED AND CIRCUITRY MADE CONTINUOUS WHERE REQUIRED.
	3	EXISTING OUTLET OR DEVICE TO REMAIN. MAINTAIN EXISTING CIRCUITING.
		ELECTRICAL CONNECTION.
		20A-125V DUPLEX RECEPTACLE, NEMA 5-20R (18" MH UNLESS NOTED OTHERWISE).
		20A-125V SINGLE RECEPTACLE, NEMA 5-20R (18" MH UNLESS NOTED OTHERWISE).
		SPECIAL PURPOSE RECEPTACLE. REFER TO NOTE ON PLAN.
		20A-125V DOUBLE DUPLEX RECEPTACLE, NEMA 5-20R, (18" MH UNLESS NOTED OTHERWISE) TWO GANG ASSEMBLY.
		20A-125V DUPLEX RECEPTACLE, NEMA 5-20R WITH BOTTOM OUTLET CONTROLLED BY WALL SWITCH, (18" MH UNLESS NOTED OTHERWISE).
		20A-125V DUPLEX RECEPTACLE, NEMA 5-20R (48" MH UNLESS NOTED OTHERWISE).
	GF	20A-125V WEATHERPROOF DUPLEX RECEPTACLE, NEMA 5-20R, WITH GROUND FAULT CIRCUIT INTERRUPTER (18" MH UNLESS NOTED OTHERWISE).
	WP	20A-125V WEATHERPROOF DUPLEX RECEPTACLE, NEMA 5-20R (HORIZONTAL 18" MH UNLESS NOTED OTHERWISE) WITH TAYMAC #10310 STANDARD COVER, VERTICAL MOUNT.
	WP GF	20A-125V WEATHERPROOF DUPLEX RECEPTACLE, NEMA 5-20R WITH GROUND FAULT CIRCUIT INTERRUPTER (18" MH UNLESS NOTED OTHERWISE), WITH TAYMAC #20310 STANDARD COVER, VERTICAL MOUNT.
	EM	20A-125V DUPLEX RECEPTACLE, NEMA 5-20R, ON EMERGENCY POWER (18" MH UNLESS NOTED OTHERWISE).
		20A-125V POWERLOCK GROUNDING TYPE RECEPTACLE, HOSPITAL USE (66" MH UNLESS NOTED OTHERWISE).
		20A-125V DUPLEX PEDestal TYPE FLOOR RECEPTACLE, NEMA 5-20R, IN HUBBELL BA-2527 FLOOR BOX WITH SA-2525 COVERPLATE AND SC-3091 HOUSING. PROVIDE CARPET FLANGE WHERE REQUIRED.
		20A-125V DUPLEX RECEPTACLE, NEMA 5-20R, IN HUBBELL BA-2527 FLOOR BOX WITH ROUND SA-3925 COVERPLATE. PROVIDE CARPET FLANGE WHERE REQUIRED.
		JUNCTION BOX.
		MULTI-OUTLET RECEPTABLES ASSEMBLY, NEMA 5-15R (SINGLE OUTLETS ON 18" CENTERS) (48" MH UNLESS NOTED OTHERWISE).
		CLOCK HANGER OUTLET, SINGLE NEMA 5-15R RECESSED IN COVER PLATE (84" MH UNLESS NOTED OTHERWISE).
		SINGLE POLE SWITCH (48" MH UNLESS NOTED OTHERWISE).
		TWO POLE WALL SWITCH (48" MH UNLESS NOTED OTHERWISE).
		THREE-WAY WALL SWITCH (48" MH UNLESS NOTED OTHERWISE).
		FOUR-WAY WALL SWITCH (48" MH UNLESS NOTED OTHERWISE).
	P	SWITCH WITH NEON PILOT LIGHT, ONE-GANG ASSEMBLY (48" MH UNLESS NOTED OTHERWISE).
	K	KEY OPERATED WALL SWITCH (48" MH UNLESS NOTED OTHERWISE).
	L	LOW-VOLTAGE MOMENTARY WALL SWITCH (48" MH UNLESS NOTED OTHERWISE).
	DM	LIGHTING DIMMER SWITCH (48" MH UNLESS NOTED OTHERWISE) 1000 WATTS UNLESS OTHERWISE INDICATED.
	R	SWITCH WITH RECEPTACLE (48" MH UNLESS NOTED OTHERWISE) STANDARD TWO-GANG ASSEMBLY OF SWITCH AND RECEPTACLE.
	M	FLUSH FRACTIONAL HORSEPOWER MOTOR STARTER WITH NEON PILOT LIGHT. ONE-GANG ASSEMBLY (48" MH UNLESS NOTED OTHERWISE).
	H	HP RATED WALL SWITCH (48" MH UNLESS NOTED OTHERWISE).
		ELECTRICAL PANEL OR SWITCHBOARD PER DRAWINGS.
	P/B	PULL BOX.
	D	DISCONNECT SWITCH.
	M	MOTOR STARTER.
	M-D	COMBINATION MOTOR STARTER AND DISCONNECT SWITCH.
		ELECTRIC MOTOR.
	UH	UNIT HEATER.
	FC	FAN COIL.
	AC	AIR CONDITIONER.
	CU	CONDENSING UNIT.
	UV	UNIT VENTILATOR.
	CR	CORD REEL.
	PP	POWER POLE.
	T	LINE VOLTAGE THERMOSTAT.
	DH	DUCT HEATER.
	EB	ELECTRIC BASEBOARD HEATER.
	M	INTERCOM SYSTEM DESK MOUNTED MASTER CONTROL STATION. SUBSCRIPT "V" INDICATES WALL MOUNT (48" MH UNLESS NOTED OTHERWISE).
	II	INTERCOM STAFF STATION (48" MH UNLESS NOTED OTHERWISE).
	HI	INTERCOM HORN TYPE SPEAKER (84" MH UNLESS NOTED OTHERWISE).
	IS	INTERCOM SPEAKER FLUSH MOUNT IN CEILING.
	OS	CEILING MOUNTED OCCUPANCY SENSOR.

	FIRE ALARM CONTROL PANEL.
	FIRE ALARM SPEAKER & SIGNAL LIGHT (80" AFF). (IF WHEN SHOWN INDICATES CANDELA RATING OF STROBE. WHEN A # IS NOT SHOWN, THE STROBE SHALL BE RATED 75 CANDELA IN CORRIDORS AND 30 CANDELA FOR ALL OTHER LOCATIONS.
	FIRE ALARM BELL & SIGNAL LIGHT (80" AFF). (IF WHEN SHOWN INDICATES CANDELA RATING OF STROBE. WHEN A # IS NOT SHOWN, THE STROBE SHALL BE RATED 75 CANDELA IN CORRIDORS AND 30 CANDELA FOR ALL OTHER LOCATIONS.
	FIRE ALARM CHIME & SIGNAL LIGHT (80" AFF). (IF WHEN SHOWN INDICATES CANDELA RATING OF STROBE. WHEN A # IS NOT SHOWN, THE STROBE SHALL BE RATED 75 CANDELA IN CORRIDORS AND 30 CANDELA FOR ALL OTHER LOCATIONS.
	FIRE ALARM HORN & SIGNAL LIGHT (80" AFF). (IF WHEN SHOWN INDICATES CANDELA RATING OF STROBE. WHEN A # IS NOT SHOWN, THE STROBE SHALL BE RATED 75 CANDELA IN CORRIDORS AND 30 CANDELA FOR ALL OTHER LOCATIONS.
	FIRE ALARM SIGNALING LIGHT (80" AFF). (IF WHEN SHOWN INDICATES CANDELA RATING OF STROBE. WHEN A # IS NOT SHOWN, THE STROBE SHALL BE RATED 75 CANDELA IN CORRIDORS AND 30 CANDELA FOR ALL OTHER LOCATIONS.
	CEILING MOUNTED FIRE ALARM SPEAKER.
	FIRE ALARM MANUAL STATION (48" MH UNLESS NOTED OTHERWISE). SUBSCRIPT "K" INDICATES KEY OPERATED.
	CEILING MOUNTED SMOKE DETECTOR.
	CEILING MOUNTED HEAT DETECTOR.
	DUCT MOUNTED SMOKE DETECTOR. SUBSCRIPT "S" INDICATES SUPPLY. SUBSCRIPT "R" INDICATES RETURN.
	DUCT MOUNTED HEAT DETECTOR. SUBSCRIPT "S" INDICATES SUPPLY. SUBSCRIPT "R" INDICATES RETURN.
	ELECTRIC RELEASE DOOR CLOSER.
	ELECTRO-MAGNETIC DOOR HOLDER.
	WATER FLOW SWITCH.
	VALVE SUPERVISORY SWITCH.
	DUCT MOUNTED DETECTOR REMOTE TEST STATION AND ALARM INDICATOR LIGHT. SUBSCRIPT "W" INDICATES WALL MOUNTED.
	SMOKE DAMPER.
	FIRE FIGHTER'S TELEPHONE (60" MH UNLESS NOTED OTHERWISE).
	PRESSURE SWITCH.
	ADDRESSABLE MODULE. SUBSCRIPT "I" INDICATES INPUT. SUBSCRIPT "C" INDICATES CONTROL.
	POST INDICATOR VALVE.
	KNOX BOX.

	LIGHTING FIXTURE. CAPITAL LETTER DENOTES FIXTURE TYPE, LOWER CASE LETTER DENOTES SWITCHING ARRANGEMENT.
	LIGHTING FIXTURE ON NIGHT LIGHT OR EMERGENCY CIRCUIT.
	EXIT LIGHTING FIXTURE, ARROWS AS INDICATED.

	<p>DETAIL: B = DETAIL DESIGNATION E2 = SHEET WHERE DETAIL IS LOCATED</p>
	<p>SECTION: 1 = SECTION DESIGNATION E2 = SHEET WHERE DETAIL IS LOCATED</p>
	<p>PLAN NOTE, APPLIES ONLY TO THE SHEET WHICH IT IS SHOWN,</p>
	<p>DETAIL NOTE, APPLIES ONLY TO THE ASSOCIATED DETAIL.</p>
	<p>CABLE TRAY, 12" x 4" DEEP UNLESS NOTED OTHERWISE.</p>
	<p>WIRE & CONDUIT IN WALL OR ABOVE CEILING.</p>
	<p>WIRE & CONDUIT IN OR BELOW SLAB OR GRADE.</p>
	<p>CONDUIT TO BE REMOVED.</p>
	<p>EXISTING WIRE & CONDUIT TO REMAIN.</p>
	<p>CONDUIT FOR DATA CIRCUITRY.</p>
	<p>WIRE & CONDUIT FOR EMERGENCY CIRCUITRY.</p>
	<p>WIRE & CONDUIT FOR FIRE ALARM CIRCUITRY.</p>
	<p>WIRE & CONDUIT FOR INTERCOM SYSTEM CIRCUITRY.</p>
	<p>WIRE & CONDUIT FOR NURSE CALL CIRCUITRY.</p>
	<p>WIRE & CONDUIT FOR NIGHT LIGHT CIRCUITRY.</p>
	<p>CONDUIT FOR PHONE CIRCUITRY.</p>
	<p>WIRE & CONDUIT FOR SOUND SYSTEM CIRCUITRY.</p>
	<p>WIRE & CONDUIT FOR SECURITY SYSTEM CIRCUITRY.</p>
	<p>WIRE & CONDUIT FOR TELEVISION SYSTEM CIRCUITRY.</p>
	<p>WIRE RUN IN SURFACE WIREWAY.</p>
	<p>CABLE MANAGEMENT SYSTEM PATHWAY.</p>
 X - 1,2	<p>EACH ARROWHEAD REPRESENTS ONE COMPLETE CIRCUIT; "X" DENOTES PANEL NAME; NUMBER(S) DENOTES CIRCUIT(S).</p>

AP	AREA ALARM PANEL - MEDICAL GAS	ID	- INSIDE DIAMETER
AC	- ACCESS	IN	- INCHES
ADJ	- ADJUSTABLE		
AF	ARC FAULT CIRCUIT INTERRUPTER	KEC	- KITCHEN EQUIPMENT CONTRACTOR
AFCI	ARC FAULT CIRCUIT INTERRUPTER		
AFB	ABOVE FINISHED FLOOR TO BOTTOM OF ITEM	L	- LENGTH
ALF	ABOVE FINISHED GRADE TO BOTTOM OF ITEM	LBS	- POUNDS
ALT	- ALTERNATE		
AP	ACCESS PANEL	MAP	- MASTER ALARM PANEL (MEDICAL GAS)
APPROX	- APPROXIMATE	MAX	- MAXIMUM
ARCH	- ARCHITECT OR ARCHITECTURAL	MEZZ	- MEZZANINE
ASSY	- ASSEMBLY	MFR	- MANUFACTURER
ATS	- AUTOMATIC TRANSFER SWITCH	MH	- MANHOLE OR MOUNTING HEIGHT TO CENTER LINE OF ITEM
		MIN	- MINIMUM OR MINUTE
BLDG	- BUILDING	MISC	- MISCELLANEOUS
BOE	- BOTTOM OF EQUIPMENT	MTD	- MOUNTED
BOT	- BOTTOM	MTG	- MOUNTING
BTWN	- BETWEEN		
		NIC	- NOT IN CONTRACT
CFCI	- CONTRACTOR FURNISHED CONTRACTOR INSTALLED	NOM	- NOMINAL
CCO	- CIRCUIT	NTS	- NOT TO SCALE
CLG	- CEILING		
CMU	- CONCRETE MASONRY UNIT	OD	- OUTSIDE DIAMETER
CONN	- CONNECT OR CONNECTION	OFCI	- OWNER FURNISHED CONTRACTOR INSTALLED
CON	- CONTRACT	OFI	- OWNER FURNISHED OWNER INSTALLED
COTR	- CONTRACTING OFFICER TECHNICAL REPRESENTATIVE		
	- CENTER	PL	- PLUMBING CONTRACTOR (DIVISION 22)
		PLBG	- PLUMBING
D	- DEPTH	PB	- PULL BOX
DET	- DETAIL		
DIA	- DIAMETER	R	- RADIUS
DM	- DIMENSION	REC	- RECESSED
DIV	- DIVISION	REQ	- REQUIRED
DN	- DOWN	ROD	- ROD/IN
DWG	- DRAWING		
		S	- SURFACE MOUNTED
EA	- EACH	SC	- SECURITY CONTRACTOR
EC	ELECTRICAL CONTRACTOR (DIVISION 26)	SCH	- SCHEDULE
EJ	- EXPANSION JOINT	SHT	- SHEET
ELEV	- ELECTRICAL	SB	- SPLICE BOX
ELV	ELEVATION OR ELEVATOR	SPEC	- SPECIFICATIONS
EM	- EMERGENCY	SS	- SQUARE
EQ	- EQUAL	STS	- STAINLESS STEEL
EQS	EQUIPMENT SUPPLIER	STD	- STANDARD
EXP	- EXISTING	STRUC	- STRUCTURAL OR STRUCTURE
EXT	- EXISTING TO REMAIN	SUC	- SUE UTILITY CONTRACTOR
EXQ	- EQUIPMENT		
EXP	- EXPANSION		
EXT	- EXTERIOR	TC	- TECHNOLOGY CONTRACTOR
		TEMP	- TEMPERATURE
FCE	- FIRE CONTROL EQUIPMENT	TOE	- TOP OF EQUIPMENT
FE	- FINISHED FLOOR ELEVATION	TYP	- TYPICAL
FLR	- FLOOR	UNE	- UNLESS NOTED OTHERWISE
FDS	- FIRE SUPPRESSION CONTRACTOR (DIVISION 21)		
FT	- FEET	VOL	- VOLUME
FTG	- FOOTING	VFD	- VARIABLE FREQUENCY DRIVE
		VOL	- VOLUME
GC	- GENERAL CONTRACTOR	W	- WITH
GFCI	- GROUND FAULT CIRCUIT INTERRUPTER	WO	- WITHOUT
GFCI	- GROUND FAULT CIRCUIT INTERRUPTER OR GOVERNMENT FURNISHED CONTRACTOR INSTALLED	WP	- WEATHERPROOF
GFFT	- GROUND FAULT FEED THRU	ZVC	- ZONE VALVE CABINET

- A. THESE NOTES APPLY EQUALLY TO THE FULL SET OF DOCUMENTS.
- B. SITE VISIT(S) SHALL BE AS OUTLINED IN PROJECT SPECIFICATIONS.
- C. INCLUDE ALL WORK NECESSARY TO ACCOMMODATE PHASING. REFER TO ARCHITECTURAL DRAWINGS AND GENERAL REQUIREMENTS SECTION 01 00 00.
- D. ALL WORK MUST BE COORDINATED WITH THE CONTRACTING OFFICER AND COTR (FOR ALL OTHERS) TO MAINTAIN OPERATION OF THE EXISTING FACILITY.
- E. ALL WORK SHALL BE PERFORMED IN COMPLETE COMPLIANCE WITH ALL CURRENT GOVERNING CODES AND STANDARDS.
- F. EXISTING CONDITIONS SHOWN HAVE BEEN BASED UPON AVAILABLE DRAWING INFORMATION, AND MAY BE AT VARIANCE WITH ACTUAL WORK IN PLACE. THE CONTRACTOR SHALL TAKE ALL NECESSARY FIELD MEASUREMENTS AND FIELD VERIFY ALL CONDITIONS AFFECTING THE EXECUTION OF THE WORK. ANY DISCREPANCIES BETWEEN EXISTING CONDITIONS AND THE WORK SHOWN ON THE CONTRACT DOCUMENTS WHICH MAY IMPACT THE PROGRESS OF THE WORK SHALL BE BROUGHT TO THE ATTENTION OF THE CONTRACTING OFFICER IN WRITING FOR RESOLUTION BEFORE PROCEEDING WITH THE WORK.
- G. ALL PENETRATIONS THROUGH FIRE-RATED ASSEMBLIES SHALL BE PROTECTED ANDNDOR FIRE-STOPPED AS REQUIRED TO MAINTAIN FIRE-RATINGS INDICATED. COORDINATE WITH ALL TRADES TO ENSURE FIRE-RATED PENETRATION REQUIREMENTS AND DETAILS ARE MET.
- H. ANNUAL SPACE OF ALL PIPE, CONDUIT, DUCT & OTHER SIMILAR PENETRATIONS OF FIRE RATED ASSEMBLIES SHALL BE FIRESTOPPED. IN ADDITION, PENETRATIONS THROUGH 4-HOUR RATED WALLS & FLOORS SHALL BE FIRESTOPPED TO RETARD PASSAGE OF FIRE & SMOKE.
- I. ALL CONDUITS IN FINISHED ROOMS, CORRIDORS, ETC. SHALL BE CONCEALED IN A WALL OR ABOVE CEILING.
- J. ACCESS PANELS IN NON ACCESSIBLE CEILINGS SHALL BE PROVIDED FOR ALL ELECTRICAL ITEMS REQUIRING ACCESS.
- K. ALL CUTTING AND PATCHING REQUIRED FOR THIS PROJECT SHALL BE INCLUDED IN THE CONTRACT. REFINISH ANY SURFACE DISTURBED UNDER THIS WORK TO MATCH EXISTING.
- L. ANY REMOVED EQUIPMENT SHALL BE TURNED OVER TO THE VA. ITEMS NOT DESIRED BY THE VA SHALL BE REMOVED FROM THE PREMISES AND DISPOSED OF PROPERLY BY THE CONTRACTOR.
- M. THE CONTRACT DRAWINGS ARE NOT INTENDED TO SHOW EVERY VERTICAL OR HORIZONTAL OFFSET WHICH MAY BE NECESSARY TO COMPLETE THE SYSTEMS. COORDINATE WORK IN ADVANCE WITH ALL OTHER TRADE AND REPORT IMMEDIATELY AND DIFFICULTIES WHICH CAN BE ANTICIPATED.
- N. ALL ABANDONED EXTRANEOUS CONDUITS, WIRING, DEVICES, ETC. SHALL BE REMOVED.
- O. REFER TO MECHANICAL DRAWINGS FOR ADDITIONAL INFORMATION CONCERNING MECHANICAL EQUIPMENT THAT REQUIRES ELECTRICAL CONNECTIONS.

18E001	SYMBOLS
18E501	DETAILS
18E601	PARTIAL PRIMARY ELECTRIC SINGLE LINE
18E602	PARTIAL BUILDING SECONDARY ELECTRIC SINGLE LINE
18ES101	ELECTRICAL SITE PLAN - REMOVALS & NEW WORK
18ED101	BASEMENT FLOOR PLAN - REMOVALS
18EP101	BASEMENT FLOOR PLAN - NEW WORK
18EL101	FIRST AND SECOND FLOOR PLANS - LIGHTING & POWER

Heapy Engineering
Mechanical Electrical Commissioning Technology
Nationally Recognized Leader in Sustainability / LEED
1400 W Dorothy Lane, Dayton OH 45409-1310
Ph: 937-224-0861 Fax: 937-224-5777 www.heapy.com
Heapy Project Number: 2012-04019 Firm License: 0152



SYMBOLS

REHAB B18
MACHINE ROOM

VA Project No.	538-12-11
JPA Project No.	12022.00
Building Number	

 Department of
Veterans Affairs

PROJECT NO. 2012-04019
DRAWN BY: JAS
PLOT/ED DATE: February 7, 2013
DAYTON/COLUMBUS, OHIO & INDIANAPOLIS, INDIANA
MECHANICAL ELECTRICAL COMMISSIONING TECHNOLOGY




three inches = one foot
one and one-half inches = one foot
one inch = one foot
one inch = one foot
three-quarters inch = one foot
one-half inch = one foot
one-eighth inch = one foot
one-eighth inch = one foot

DETAIL NOTES

- 3000 LB. CONCRETE ENCASEMENT.
- 4" I.D. DUCTS, SCHEDULE 40 PVC.
- MIN. 3" SPACING BETWEEN CONDUITS AND MIN. 3" ENCASEMENT (TYPICAL). PROVIDE CONDUIT SPACERS 6'-0" O.C.
- REFER TO SPECS FOR TYPE OF MARKER TAPE
- 1" I.D. DUCT, SCHEDULE 40 PVC.
- 1.5" DUCT, SCHEDULE 40 PVC.


NORMAL UNDERGROUND DUCTS

SCALE: NONE



OPTIONAL STANDBY/EMERGENCY UNDERGROUND DUCTS

SCALE: NONE




DETAIL NOTES

- 3000 LB. CONCRETE ENCASEMENT. 3" MIN. FROM OUTSIDE OF DUCT.
- 4" I.D. DUCT, SCHEDULE 40 PVC.
- REFER TO SPECS FOR TYPE OF MARKER TAPE


UNDERGROUND DUCTS

SCALE: NONE



GENERATOR START CIRCUIT DETAIL


SCALE: NONE



GENERAL NOTES

- MATERIAL AND COMPACTION REQUIREMENTS FOR PIPE BEDDING/SHADING SHALL BE IN ACCORDANCE WITH THE SPECIFICATIONS FOR THE APPLICABLE UTILITY PIPE.
- TRENCH BACKFILL SHALL COMMENCE 1 FOOT [305mm] ABOVE THE TOP OF PIPE.
- BACKFILL COMPACTION REQUIREMENTS SHALL COMPLY TO VA SPECIFICATIONS.
- THE 1 FOOT [305mm] TRENCH "SHOULDER" AREAS SHALL BE DELETED FOR TYPE 2 TRENCHES.
- PORTLAND CEMENT CONCRETE SHALL BE IN ACCORDANCE VA SPECIFICATION REQUIREMENTS.
- ASPHALTIC TACK MATERIAL SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS OF VA SPECIFICATION REQUIREMENTS.
- ASPHALTIC CONCRETE SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS OF VA SPECIFICATION REQUIREMENTS.
- LOAD TRANSFER DOWELS FOR JOINTS TRANSVERSE TO THE ROADWAY CENTERLINE SHALL BE SMOOTH STEEL DOWELS IN ACCORDANCE WITH THE REQUIREMENTS OF VA SPECIFICATION REQUIREMENTS. DOWELS SHALL BE SIZED AND SPACED AS FOLLOWS:


PCCP THICKNESS	DOWEL SIZE	DOWEL LENGTH	DOWEL SPACING
6" [150mm]	#5 [No. 16]	12" [305mm]	18" [455mm]
7" [180mm]	#6 [No. 19]	15" [380mm]	15" [380mm]
8" [180mm]	#8 [No. 19]	15" [380mm]	12" [305mm]
10" [180mm]	#10 [No. 19]	15" [380mm]	12" [305mm]
- DEFORMED TIE BARS SHALL BE USED IN TRENCH PATCHES LONGITUDINAL TO THE ROADWAY CENTERLINE WHEN THE TRENCH LENGTH IS GREATER THAN 50 FEET [15240mm]. TIE BARS SHALL BE 24 INCHES [610mm] LONG. DEFORMED #4 [No. 13] BARS FOR PCPP LESS THAN 8 INCHES [205mm] THICK AND #5 [No. 16] BARS IF 8 INCHES [205mm] THICK OR MORE. TIE BARS SHALL BE PLACED 30 INCHES [760mm] CENTER-TO-CENTER.
- HOLES SHALL BE DRILLED 1 FOOT [305mm] INTO THE EXISTING SLAB FOR TIE BARS AND 7 INCHES [180mm] FOR DOWELS. HOLES SHALL BE OF A DIAMETER SUFFICIENT TO ACCOMMODATE THE TIE BAR ANCHORAGE OR DOWEL CAP. TIE BARS SHALL BE ANCHORED WITH AN APPROVED HIGH VISCOSITY EPOXY.
- IF THE CONCRETE SLAB REMAINING NEXT TO A LONGITUDINAL OR TRANSVERSE JOINT IS LESS THAN 6 FEET [1829mm] AT ITS NARROWEST WIDTH, REMOVE AND REPLACE THE EXISTING CONCRETE TO THE JOINT.



- 2" [50mm] MINIMUM OR THICKNESS OF EXISTING PAVEMENT WHICHEVER IS GREATER.
 - BITUMINOUS SURFACE TREATMENT (CHIPSEAL) REQUIRED ONLY FOR LONGITUDINAL TRENCHES WITH WIDTHS GREATER THAN 6' [1829mm].
 - 4" [100mm] MINIMUM ABC OR THICKNESS OF EXISTING GRANULAR BASE COURSE MATERIALS (E.G. ABC & SELECT MATERIAL) WHICHEVER IS GREATER.
- REFER TO VA STANDARD DETAIL 32 12 16-04 "UTILITY TRENCH PAVEMENT PATCH NOTES" FOR ADDITIONAL INFORMATION.

ASPHALT REPAIR DETAIL

SCALE: NONE



CHAIN HUNG INDUSTRIAL FIXTURE.


- CHANNEL:** 20 GAGE STEEL FINISHED INSIDE AND OUTSIDE WITH BAKED WHITE ENAMEL AND WIRE GUARD.
- REFLECTOR:** 20 GAGE STEEL WITH WHITE ENAMEL FINISH INSIDE AND OUT. APERTURED FOR 10% UPLIGHT.
- END CAPS:** 20 GAGE STEEL FINISHED TO MATCH CHANNEL.
- BALLAST:** TWO LAMP, HPF, ELECTRONIC TYPE AS SPECIFIED, UNIVERSAL VOLTAGE (277V/120V)
- LAMPHOLDER:** TURRET TYPE.
- LAMP:** TWO 32, T8 RAPID START 4100K FLUORESCENT, MIN 84 CRI.
- MOUNTING:** SURFACE OR CHAIN HUNG AT 7'-6" AFF.

FLUORESCENT INDUSTRIAL FIXTURE

E
F-7

CONSULTANTS:

Heapy Engineering
Mechanical Electrical Commissioning Technology
Nationally Recognized Leader in Sustainability / LEED
1400 W Dorothy Lane, Dayton OH 45409-1310
Ph: 937-224-0861 Fax: 937-224-5777 www.heapy.com
Heapy Project Number: 2012-04019 Firm License: 01528



ARCHITECT/ENGINEERS:

RDC/JOHN POE ARCHITECTS


150 ERENWOLD DRIVE
BALTIMORE, MD 21202
410-862-3880 PHONE
410-862-3880 FAX
joe@johnpoe.com

Drawing Title
DETAILS
Approved: Project Director

Project Title
REHAB B18 MACHINE ROOM
Location
Chillicothe, Ohio
Date
12/27/2012
Checked
MSG
Drawn
JAS


Project No.
VA Project No. 538-12-119
JPA Project No. 12022.00
Building Number
18
Drawing Number
18E501
Dwg. of

Office of Construction and Facilities Management
Department of Veterans Affairs



ALL LIGHT LINEWEIGHTS INDICATE EXISTING EQUIPMENT TO REMAIN. DASHED LINEWEIGHTS INDICATES EQUIPMENT TO BE REMOVED. DARK LINEWEIGHT INDICATES NEW WORK.

Office of
Construction
and Facilities
Management

 Department of
Veterans Affairs



A. SEQUENCE OF CONSTRUCTION INDICATED BELOW IS ONE POSSIBLE SOLUTION TO THE PROBLEM OF THE BUILDING ELECTRICAL SYSTEM. CONTRACTOR IS REQUIRED TO SUBMIT A DETAILED SEQUENCE OF OPERATION TO THE COTR AT THE BEGINNING OF THE PROJECT. SEQUENCE MUST BE APPROVED BY THE COTR BEFORE THE CONTRACTORS ARE PERMITTED TO COMMENCE WORK. DEVIATIONS FROM THE FOLLOWING PROPOSED SEQUENCE OF CONSTRUCTION WILL BE REVIEWED, BUT WILL NOT BE GROUNDS FOR ADDITIONAL COST TO THE GOVERNMENT.

- B. ALL CUT OVER WORK DOWNTIME SHALL BE DONE OUTSIDE OF NORMAL WORKING HOURS (NIGHTS AND WEEKENDS).
- C. COORDINATE DOWNTIME SCHEDULES WITH COTR MINIMUM OF 30 DAYS IN ADVANCE FOR PROPER COORDINATION.
- D. REFER TO FLOOR PLANS AND SINGLE LINE FOR ADDITIONAL INFORMATION.
- E. CONTRACTOR SHALL FIELD VERIFY EXACT LOCATION OF ALL UNDERGROUND UTILITIES WITHIN AFFECTED AREAS/SCOPE OF WORK. THIS WORK SHALL BE PERFORMED PRIOR TO ANY EXCAVATION WORK. CONTRACTOR MUST USE A PROPER UNDERGROUND UTILITY LOCATING SERVICE AND SUBMIT ALL FINDINGS TO THE COTR WITH DOCUMENTED SEQUENCE OF CONSTRUCTION FOR REVIEW.
- F. ANY DAMAGE TO EXISTING UTILITIES SHALL BE REPAIRED BY THE CONTRACTOR AT AN ADDITIONAL COST TO THE GOVERNMENT.
- G. RECOMMEND HYDRO-EXCAVATION TO MINIMIZE DAMAGE TO UNKNOWN UNDERGROUND UTILITIES NOT LOCATED DURING INVESTIGATION.
- H. ALL CIRCUITRY IS SHOWN FROM AS-BUILT DRAWINGS. FOR REFERENCE ONLY. UPDATE ON AS BUILT DRAWINGS WHEN LOCATED.
- I. PROVIDE ALL EXCAVATION, RIGGING, BACKFILL, GRADING, SEEDING, SURFACE RESTORATION, ETC., AS REQUIRED TO RETURN ALL WORK BACK TO ORIGINAL CONDITIONS.

PHASE I:

- d. ALL EXISTING UNDERGROUND UTILITIES ARE TO BE MARKED, DEPTH LOCATED, IN AREAS WHERE TWO DUCTRUNKS ARE TO CROSS OR OVERLAP. SERVICE IS LOCATED.
- e. SAW CUT BLOCK WALL (FROM AVENUE, ROAD SIDE) TO GAIN ACCESS TO THE GROUND-STAR (AVENUE AREA). EXCAVATE THE AREA NEAR B12 STAR QUARTY FOUNDATION WALL.
- f. SUBMIT COORDINATION DRAWINGS SHOWING ALL PROPOSED CONDUIT (2" AND LARGER) EQUIPMENT, ETC., FOR APPROVAL BY COTR AND ELECTRICAL ENGINEER.
- g. ROUGH-IN NEW 800A DISTRIBUTION PANEL "MDP-1A", SERVICE ENTRANCE RATED AUTOMATIC TRANSFER SWITCH AND FEEDER CONNECTING THE TWO IN EXISTING ELECTRIC ROOM. ROUGH-IN NEW PRIMARY CONDUIT AND FEEDER FROM MDP-1A AND MAIN DISCONNECT SWITCH TO NEW TRANSFORMER CONCRETE PAD LOCATION. ROUGH-IN NEW SECONDARY CONDUIT AND FEEDERS FROM TRANSFORMER CONCRETE PAD LOCATION TO EXISTING ELECTRIC ROOM AND TERMINATE TO NEW SERVICE ENTRANCE ATS.
- h. ROUGH-IN NEW EMERGENCY CONDUITS AND FEEDERS (LIFE SAFETY AND OPTIONAL STANDBY) FROM NEW GENERATOR CONCRETE PAD LOCATION TO EXISTING ELECTRIC ROOM AND TERMINATE OPTIONAL STANDBY FEEDER TO NEW SERVICE ENTRANCE ATS. SUB LIFE SAFETY CONDUIT AND FEEDER IN TO MAIN ELECTRIC ROOM FOR FUTURE ELECTRICAL.
- i. ROUGH-IN NEW FEEDER FROM DISTRIBUTION PANEL "MDP-1A" AND SUB TO EXISTING DISTRIBUTION PANEL "MDP-1".
- j. ROUGH-IN NEW FEEDERS FROM DISTRIBUTION PANEL "MDP-1A" AND TERMINATE TO TWO (2) NEW 5-TON COOLING UNITS LOCATED IN THE EXISTING SERVICE ROOM.

Phase II:

- a. PROVIDE AND SET TEMPORARY 80KW (278A, 2009/12/05-3PM-4PM) GENERATOR WITH OVERLOAD PROTECTION AND TEMPORARY FEEDERS FOR TEMPORARY POWER TO DISTRIBUTION PANEL "MBP08A10X" (FEEDING UPS) DURING CUTOVER. COORDINATE PATH OF TEMPORARY FEEDERS THRU EXISTING HIGH/VOLTAGE ROOMS TO ACCESS "MBP08A10X". TEMPORARY FEEDERS SHALL BE LAID ON FLOOR DURING CUTOVER. PROTECT FEEDERS WHERE ACCESSIBLE TO PUBLIC/PEDESTRIAN TRAFFIC.
- b. VA SHALL DETERMINE ALL NON-ESSENTIAL LOADS TO TURN OFF WITHIN SERVER ROOM TO EXTEND UPS BATTERY LIFE (BACKUP TIME). COORDINATE WORK HAS BEEN COMPLETED WITH COTR PRIOR TO CUTOVER OF TEMPORARY POWER.
- c. UTILIZE UPS POWER (APPROX. 25 MIN OF BETTERY BACKUP) DURING CUTOVER TO TEMPORARY GENERATOR.

Phase III:

- a. SET NEW 225 KVA TRANSFORMER AND 200 KW EMERGENCY GENERATOR. TEST GENERATOR AND TRANSFORMER FUNCTIONALITY TO SATISFACTION OF COITC ENGINEER. ALL TESTS SHALL BE COMPLETED PRIOR TO ANY CONNECTION TO CAMPS PRIMARY OR BULB FEEDERS.
- b. ONCE TESTING STANDARDS HAVE BEEN MET TO PROPER STANDARDS, TERMINATE AND ASSOCIATE CONDUCTORS TO TRANSFORMER AND GENERATOR. PROVIDE WRITTEN VERIFICATION TO COIT THAT ALL PHASES OF GENERATOR HAVE BEEN VERIFIED WITH TESTS TO CONDUCTORS PRIOR TO TERMINATIONS.
- c. OPEN SWI SWITCH IN PM5626 SERVING PM18A AND PM18A. MAXIMUM DOWNTIME OF BUILDING POWER SHALL BE NO MORE THAN 4 HOURS TO COMPLETE REMAINING PHASES. IF SUCCESSFUL CONTRACTOR IS RESPONSIBLE FOR PROVIDING ADEQUATE STAFF TO ACCOMMODATE THIS WORK WITHIN THE 4 HOUR WINDOW.
- d. TERMINATE NEW FEEDER TO EXISTING DISTRIBUTION PANEL "PD"-1.
- e. VERIFY SERVICE ENTRANCE ATS IS IN THE "EMERGENCY" AND BYPASS POSITION AND START NEW 200 KW EMERGENCY GENERATOR ENERGIZING THE NEW DISTRIBUTION PANEL "MDP"-1A.
- f. CONTRACTOR TO PROVIDE TEMPORARY LIGHTING IN POLICE DISPATCH WITHIN THE 4 HOUR DOWNTIME OF BUILDING POWER.

Phase IV:

- a. INTERCEPT ALL EXISTING LOADS FED FROM EXISTING "MDP-1" AND EXTEND TO NEW 800A DISTRIBUTION PANEL "MDP-1A".
- b. INTERCEPT EXISTING "MDP-2" AND EXTEND TO NEW 800A DISTRIBUTION PANEL "MDP-1A".

Phase V:

- a. TERMINATE PRIMARY FEEDER WITHIN PMSG25 AND CLOSE TO ENERGIZE NORMAL POWER TO BUILDING 18.
- b. SWITCH NEW S.E.A.TS TO "NORMAL" POSITION AND SHUT DOWN EMERGENCY GENERATOR.

Phase VI:

- d. REMOVE ALL EXISTING EQUIPMENT, TRANSFORMERS, GENERATOR, FEEDERS, CONDUITS AND CONCRETE PADS NO LONGER BEING USED ASSOCIATED WITH THIS WORK.


Phase VII:

- a. INSTALL NEW EMERGENCY PANEL, ATS AND CONNECTING FEEDER.

1. REMOVE EXISTING EMERGENCY GENERATOR, CONCRETE PAD AND ASSOCIATED UNDERGROUND FEEDER/CONDUIT. REFER TO SEQUENCE OF CONSTRUCTION FOR PHASING.
2. REMOVE EXISTING TRANSFORMER, CONCRETE PAD AND ASSOCIATED UNDERGROUND FEEDER/CONDUIT. REFER TO SEQUENCE OF CONSTRUCTION FOR PHASING.
3. NEW EMERGENCY GENERATOR. REFER TO NEW WORK FLOOR PLANS FOR ADDITIONAL DETAILS.
4. NEW PAD MOUNTED TRANSFORMER. REFER TO NEW WORK FLOOR PLANS FOR ADDITIONAL DETAILS.
5. EXISTING PAD MOUNTED PRIMARY ELECTRIC SWITCH.
6. EXISTING UNDERGROUND STEAM LINES/TUNNEL TO REMAIN. PROVIDE REINFORCING OF DUCTBANK WHERE IT CROSSES STEAM LINE TUNNEL. COORDINATE REINFORCING MEANS WITH COTR PRIOR TO INSTALLATION.
7. EXISTING UNDERGROUND STORM PIPING TO REMAIN.
8. EXISTING UNDERGROUND SANITARY PIPING TO REMAIN.
9. EXISTING UNDERGROUND FIRE ALARM/DATA CONDUIT TO REMAIN.
10. EXISTING UNDERGROUND WATER PIPING TO REMAIN.
11. EXISTING UNDERGROUND ELECTRIC TO REMAIN.
12. REMOVE EXISTING UNDERGROUND FUEL STORAGE TANK (T17), FILL PIPE, FUEL LINES (BOTH SUPPLY & RETURN), FUEL GUAGE, ETC. BACKFILL EARTH AND RESTORE GRADE TO MATCH EXISTING CONDITIONS
13. REMOVE SCHNEIDER ELECTRIC ATS/GENERATOR PT/CT PULLBOX AND ALL CONDUIT/CABLING.
14. SITE GRADING/RETAINING WALL WORK. REFER TO ARCHITECTURAL PLANS.
15. ELECTRICAL ROOM. REFER TO 1/8" PLANS FOR EQUIPMENT LOCATIONS.
16. RUN ELECTRICAL CONDUITS THRU BELOW STAIR CAVITY.
17. CORE DRILL EXISTING WALL, OR INSTALL BELOW FOOTER, FOR ENTRANCE INTO THE EXISTING ELECTRICAL ROOM. EXCAVATION OF THE ASPHALT WILL EXPOSE ELEVATION REQUIRED TO ENTER THE BUILDING.
18. SLOPE NEW FEEDERS AWAY FROM BUILDING. REFER TO SHEET 180501 FOR UNDERGROUND CONDUIT DETAILS.
19. INSTALL NEW PRIMARY FEEDER MINIMUM OF 30" BELOW GRADE (PER NEC 1300.50).
20. REMOVE EXISTING ABANDONED UNDERGROUND CONDUIT BACK TO MANHOLE AS INDICATED.
21. REMOVE EXISTING UNDERGROUND SKV PRIMARY FEEDER, CONDUIT AND DUCTBANK. REFER TO SEQUENCE OF CONSTRUCTION.
22. REMOVE EXISTING GENERATOR FUEL MONITORING EQUIPMENT, CONDUIT, WIRING, WEATHERPROOF ENCLOSURE AND SUPPORT BRACK.
23. REMOVE EXISTING UNDERGROUND GENERATOR FEEDER. REFER TO SEQUENCE OF CONSTRUCTION FOR PROPER PHASING.
24. REMOVE UNDERGROUND SKV PRIMARY FEEDER.
25. REMOVE UNDERGROUND FUEL PIPING.
26. PROVIDE ALL SAW CUTTING AND PATCHING OF EXISTING CONCRETE SIDEWALK. REMOVE AND REPLACE ENTIRE PAVES.
27. PROVIDE ALL SAW CUTTING AND PATCHING OF EXISTING ASPHALT DRIVEWAY.
28. PROVIDE ALL SAW CUTTING AND PATCHING OF EXISTING CONCRETE CURBS.
29. REMOVE EXISTING UNDERGROUND SECONDARY FEEDER. REFER TO SEQUENCE OF CONSTRUCTION FOR PROPER PHASING.


[illegible]

CONSULTANTS:



ARCHITECT/ENGINEERS

RDC/JOHN POE ARCHITECTS



	Drawing Title
--	---------------

ELECTRICAL SITE PLAN
REMOVAL & NEW WORK

Approved: Project Director

Project Title

REHAB B18
MACHINE ROOM

Location

☐ Checked

Drawn

Project No.

VA Project No.	538-12-119
JPA Project No.	12022.00
Building Number	18

Drawing Num


TEST 101

Dwg. of


Office of
Construction
and Facilities
Management




three-eighths inch = one foot
one-half inch = one foot
one-quarter inch = one foot
one-eighth inch = one foot



BASEMENT FLOOR PLAN - POWER REMOVALS
SCALE: 1/8" = 1'-0"



SITE PHOTOGRAPH 8
SCALE: NONE



SITE PHOTOGRAPH 7
SCALE: NONE



SITE PHOTOGRAPH 11
SCALE: NONE



SITE PHOTOGRAPH 9
SCALE: NONE



SITE PHOTOGRAPH 10
SCALE: NONE



SITE PHOTOGRAPH 6
SCALE: NONE



SITE PHOTOGRAPH 5
SCALE: NONE



SITE PHOTOGRAPH 1
SCALE: NONE



SITE PHOTOGRAPH 2
SCALE: NONE



SITE PHOTOGRAPH 3
SCALE: NONE



SITE PHOTOGRAPH 4
SCALE: NONE



SITE PHOTOGRAPH 17
SCALE: NONE

- GENERAL NOTES**
- A. REMOVE ALL EXISTING WORK WHICH WILL BE SUPERFLUOUS WHEN THE NEW SYSTEM IS INSTALLED AND MADE OPERATIONAL. NOT ALL ITEMS THAT NEED TO BE REMOVED ARE NECESSARILY SHOWN ON THE DRAWINGS. VOID UNUSED CONDUIT BEHIND WALLS OR BELOW FLOORS AS NECESSARY OR AS DIRECTED. NO WIRE OR CONDUIT SHALL BE REMOVED WHICH WILL IMPAIR THE FUNCTIONING OF THE REMAINING WORK UNLESS FIRST REPLACED WITH A REROUTED SECTION OF WIRE OR CONDUIT TO ENSURE CONTINUITY. REMOVE INACTIVE WIRING BACK TO THE LAST ACTIVE JUNCTION BOX, PANELBOARD OR PIECE OF EQUIPMENT.
 - B. UPON COMPLETION, NO UNUSED CONDUIT OR STUB SHALL EXTEND THRU FLOORS, WALLS OR CEILINGS IN FINISHED AREAS. ABANDONED CONDUIT WHERE REMAINING IN PLACE SHALL HAVE ANY UNUSED WIRING REMOVED. ALL ACCESSIBLE UNUSED CONDUIT SHALL BE REMOVED.
 - C. WHEN IT IS NECESSARY TO REROUTE A SECTION OF AN ACTIVE CIRCUIT, THE REROUTED SECTION SHALL BE INSTALLED BEFORE REMOVING THE EXISTING IN ORDER TO MINIMIZE SYSTEM DOWN TIME. REROUTED SECTIONS SHALL BE INSTALLED AS REQUIRED FOR NEW WORK.
 - D. MAINTAIN LIGHTING AND RECEPTACLE CIRCUITS FOR NEW WORK (WHERE INDICATED AND/OR REQUIRED).
 - E. REMOVE ALL ACCESSIBLE ABANDONED WIRING OF ALL TYPES, OR CAP AND LABEL IN JUNCTION BOX FOR RE-USE. ASSOCIATED WORK SHALL BE DONE IN COMPLIANCE WITH THE NATIONAL ELECTRIC CODE.
 - F. MAINTAIN AND RESTORE, IF INTERRUPTED, ALL CONDUITS AND CONDUCTORS PASSING THRU RENOVATED AREAS SERVICING UNDISTURBED AREAS.
 - G. MAINTAIN EXISTING FIRE ALARM DEVICES AS INDICATED FOR RELOCATION UNDER NEW WORK PHASE.

- NOTES**
- 1. REMOVE EXISTING BRICK LAYERING ON TOP OF EXISTING BLOCK WALL. PATCH AND/OR REPAIR EXISTING BLOCK WALL AS DAMAGE IS REVEALED.
 - 2. REMOVE PORTIONS OF EXISTING PLYWOOD BACKBOARD AS REQUIRED TO ACCOMMODATE NEW DISTRIBUTION PANEL.
 - 3. REMOVE EXISTING CONCRETE CURB. PROVIDE NEW CONCRETE SKIM WORK AS NECESSARY TO MATCH EXISTING.
 - 4. REMOVE EXISTING OVERHEAD FEEDER TO EXISTING DISTRIBUTION PANEL "MDP-2".
 - 5. REMOVE PORTION OF EXISTING BLOCK WALL TO CREATE ACCESS INTO CRAWL SPACE/STAIR CAVITY TO ACCOMMODATE NEW WORK.
 - 6. REMOVE EXISTING EMERGENCY GENERATOR, CONCRETE PAD AND ASSOCIATED UNDERGROUND FEEDER/CONDUIT.
 - 7. REMOVE EXISTING TRANSFORMER, CONCRETE PAD AND ASSOCIATED UNDERGROUND FEEDER/CONDUIT.
 - 8. REMOVE AND RELOCATE EXISTING FIRE OPTIC CABLE AND L.L.U. (LIGHT INTERFACE UNIT) EQUIPMENT AS REQUIRED TO ACCOMMODATE NEW DISTRIBUTION PANEL. UTILIZE SERVICE LOOP SLACK IN EXISTING CABLE.
 - 9. MAINTAIN EXISTING J.A.C.E. (JAVA APPLICATION CONTROL ENGINE) EQUIPMENT CONTROL PANEL.
 - 10. REMOVE EXISTING SURFACE MOUNTED RECEPTACLE.
 - 11. REMOVE EXISTING BATTERY WALL PACK LIGHTING FIXTURE.
 - 12. REWORK/EXTEND SURFACE MOUNTED CONDUIT AND JUNCTION BOX TO ALLOW FOR REMOVAL OF EXISTING BRICK.
 - 13. RELOCATE SURFACE MOUNTED JUNCTION BOX AND CONDUIT(CONTROL CIRCUITS) TO ALLOW FOR INSTALLATION OF NEW DISTRIBUTION PANEL. WORK SHALL BE PERFORMED BY AUTHORIZED DDC REPRESENTATIVE.
 - 14. REMOVE EXISTING LIGHT FIXTURE.
 - 15. REMOVE EXISTING UNDERGROUND FUEL STORAGE TANK, ASSOCIATED PIPING, INVENTORY LEAK MONITORING PANEL, BACKBOARD, HORN, SIREN, ETC. RESTORE GRADE TO MATCH EXISTING CONDITIONS.
 - 16. REMOVE EXISTING UNDERGROUND FEEDER AND CONDUIT. REFER TO SITE PLAN AND SEQUENCE OF CONSTRUCTION FOR ADDITIONAL INFORMATION.
 - 17. REMOVE EXISTING FENCE.


Revisions	Date	CONSULTANTS:	 Heapy Engineering Mechanical Electrical Commissioning Technology Nationally Recognized Leader in Sustainability / LEED 1400 W Dorothy Lane, Dayton OH 45409-1310 Ph: 937-224-0861 Fax: 937-224-5777 www.heapy.com Heapy Project Number: 2012-04019 Firm License: 01528	 JOHN A. BLACK REGISTERED PROFESSIONAL ENGINEER STATE OF OHIO	ARCHITECT/ENGINEERS: RDC/JOHN POE ARCHITECTS 530 EERNWISD SHIRRET BALTIMORE/DESIGN/MD/222/FLORIDA 32701 800 862 3880 PHONE 800 862 3880 FAX joe@rdcpoe.com	Drawing Title BASEMENT FLOOR PLAN REMOVALS Approved: Project Director	Project Title REHAB B18 MACHINE ROOM Location Chillicothe, Ohio Date 12/27/2012 Checked MSG Drawn JAS	Project No. VA Project No. 538-12-119 JPA Project No. 12022.00 Building Number 18 Drawing Number 18ED101 Dwg. of	Office of Construction and Facilities Management
-----------	------	--------------	--	--	---	--	---	---	---


three-eighths inch = one foot
one-half inch = one foot
one-quarter inch = one foot
one-eighth inch = one foot



SCALE: 1/8" = 1'-0"

CONSULTANTS:	
<div>Heapy Engineering Mechanical Electrical Commissioning Technology <i>Nationally Recognized Leader in Sustainability / LEED</i> 1400 W Dorothy Lane, Dayton OH 45409-1310 Ph: 937-224-0861 Fax: 937-224-5777 www.heapy.com Heapy Project Number: 2012-04019 Firm License: 01528</div>	



Project Title REHAB B18 MACHINE ROOM			Project No. VA Project No. 538-12-119 JPA Project No. 12022-00		<div>Office of Construction and Facilities Management</div> <div>  Department of Veterans Affairs </div>
Location Chillicothe, Ohio			Building Number 18		
Drawing Number 18EP101			Dwg. of		
Date 12/27/2012	Checked MSG	Drawn JAS			

